



# IJEAST

INTERNATIONAL JOURNAL  
OF ENGINEERING APPLIED SCIENCE  
AND TECHNOLOGY



VOLUME : 9    ISSUE : 11    Print / Issue Publication Date: 28-Apr-2025



ISSN : 2455-2143



DOI : 10.33564/IJEAST.2025.v09i11.003

Indexed In



[WWW.IJEAST.COM](http://WWW.IJEAST.COM)

[editor@ijeast.com](mailto:editor@ijeast.com)



# AN OVERVIEW OF STEAM BOILERS CHEMICAL TREATMENT STRATEGIES

Sasikumar Santhanamarisamy  
 Senior Design Engineer – Mechanical Engineering,  
 Fluor Daniel India Private Limited,  
 Infinity Tower B, 6 th Floor, DLF Cyber city,  
 DLF Phase II, Gurugram-122002

**Abstract—** The Feed water usage in Boiler has the limitation for Iron, Copper, Total hardness Silica and dissolved solids. The operation of the Boiler will be affected due to the presence of Calcium and Magnesium salts in the water. The presence of excess Oxygen and Carbon dioxide in Boiler feed water tend to make corrosion in the Boiler parts. The use of chemicals in treating Boiler water tend to improve the Boiler efficiency, reduced maintenance cost, increased Equipment life, reduce the Fuel cost and minimize the water usage. When the Boiler water becomes steam which leaves the impurities like salts of calcium and Magnesium and the same impurities shall be removed from the Boiler by blowdown and addition of makeup water. This paper outlines detrimental effects of dissolved salts, ions and gases present in the Boiler feed water and condensate water and remedial solution such as chemical treatment strategies which eventually increases the life of the Boiler system.

## I. INTRODUCTION

This is brief write up on the steam boiler water treatment. The Boiler operators require effective Boiler feed water treatment system to maintain the Boiler. The main objective of this write up is to provide the Boiler users to operate and maintain the boiler in a efficient way to improve the efficiency and ways to prevent the boiler from any mishappening.

The impurities exists in water are of three types and can cause multiple problems in boilers. These impurities are

1. Suspended solids
2. Dissolved solids
3. Dissolved gasses.

Impurities present in the water can be treated by usually physical or mechanical methods. Chemical treatment is to clean up the remaining traces left after physical treatment. The pre-treatment (Physical or Mechanical) minimize chemical costs.

Faulty water chemistry results in Corrosion in tubes and pipes, Scale formation in Tubes and Carry over impurities. These needs to be taken care while required high performance.

Scaling is formed by salts in water. These salts reach a deposit site and precipitate when concentrated by increase in temperature in Boilers. Common impurities that can form scale shall be Magnesium, calcium, iron, copper and silica. The deposits formed by the following ways:

- scale that deposited onto tube surfaces
- sludge which were carried away by water to the metal surface

Some common scales in Boiler water systems are:

- calcium carbonate
- calcium phosphate
- magnesium silicate
- silica

As per ASME/ABMA ( American Boiler Manufacturers Association):  
**Boiler Feed water Quality shall be as follows:**

**Table 1:**

| Boiler Operating pressure(bar) | Total dissolved solids (ppm) | Total Alkalinity (ppm) | Total Suspended Solids (ppm) |
|--------------------------------|------------------------------|------------------------|------------------------------|
| 0-3.5                          | 2500                         | 500                    | -                            |
| 3.5-20                         | 3500                         | 700                    | 15                           |
| 20-30                          | 3000                         | 600                    | 10                           |
| 30-40                          | 2500                         | 500                    | 8                            |
| 40-50                          | 1000                         | 200                    | 3                            |
| 50-60                          | 750                          | 150                    | 2                            |
| 60-70                          | 625                          | 125                    | 1                            |

**Boiler water quality after Dearator:**

**Table 2:**

| Drum Design pressure (psig) | Dissolved oxygen (ppm) | Toal Iron (ppm) | Total copper(ppm ) | Total hardness (ppm) | pH      | Non voltaile TOC (ppm) | Oily matter (ppm) |
|-----------------------------|------------------------|-----------------|--------------------|----------------------|---------|------------------------|-------------------|
| 0-300                       | <0.007                 | ≤0.1            | ≤0.05              | ≤0.3                 | 8.3-10  | <1                     | <1                |
| 301-450                     | <0.007                 | ≤0.05           | ≤0.025             | ≤0.3                 | 8.3-10  | <1                     | <1                |
| 451-600                     | <0.007                 | ≤0.03           | ≤0.02              | ≤0.2                 | 8.3-10  | <0.5                   | <0.5              |
| 601-750                     | <0.007                 | ≤0.025          | ≤0.02              | ≤0.2                 | 8.3-10  | <0.5                   | <0.5              |
| 751-900                     | <0.007                 | ≤0.02           | ≤0.015             | ≤0.1                 | 8.3-10  | <0.5                   | <0.5              |
| 901-1000                    | <0.007                 | ≤0.02           | ≤0.01              | ≤0.05                | 8.8-9.6 | <0.2                   | <0.2              |
| 1001-1500                   | <0.007                 | ≤0.01           | ≤0.01              | ≤0.05                | 8.8-9.6 | <0.2                   | <0.2              |
| 1501-2000                   | <0.007                 | ≤0.01           | ≤0.01              | ≤0.05                | 8.8-9.6 | <0.2                   | <0.2              |

**Boiler Feedwater-Maximum Allowable impurities**

**Table 3:**

| Chemical         | Symbol                          | Maximum concentration (ppm) |
|------------------|---------------------------------|-----------------------------|
| Sodium Sulphite  | Na <sub>2</sub> So <sub>3</sub> | 1                           |
| Sodium Chloride  | NaCl                            | 10                          |
| Sodium Phosphate | Na <sub>3</sub> PO <sub>4</sub> | 25                          |
| Sodium Sulphate  | Na <sub>2</sub> So <sub>4</sub> | 25                          |
| Silica Oxide     | SiO <sub>2</sub>                | 0.2                         |

## II. CHEMICAL DOSING REQUIREMENT

Because of water hardness and its composition interactions with treatment chemicals and other impurities it is very hard to determine the true concentrations of many impurities in the boiler water.

Chlorides, which are relatively unaffected by other materials in the boiler. When compared to the makeup water chloride concentration, boiler water chloride concentration will show the cycles of concentration of a boiler Feed water. In Boiler Blowdown in based on the composition of chlorides present in the water. If “N” of cycles of concentration is advised for a given boiler, then the concentration of chlorides should never exceed “N” times that of the makeup water. For example, the makeup water chloride concentration is 6 ppm so the boiler chloride concentration must never exceed 36 ppm.

The way to reduce the cycles of concentration in boilers is to blow down some of the highly concentrated boiler water. Makeup water replaces the blow down and dilutes the remaining boiler water. Blow down is performed two ways.

1. Surface blowdown and
2. Bottom blowdown.

Surface blowdown normally controls through the manual valve. This process can also be automated by use of a conductivity sensor, motorized valve, and controller. This method will control water quality through the automated valve as needed.

Bottom blowdown is typically performed every shift on each blowdown connection. Bottom blowdown removes the boiler of sludge and sediment at the bottom of the boiler. This makes it imperative that each boiler blowdown connection is used to prevent accumulation of sludge and solids in that part of the boiler. Considering the boiler load profile, water quality, and the chemical treatment program, the frequency and duration of bottom blowdown can be calculated.

The blow down should be done based on the water quality and the steam quality. If the entire blow down is done manually, as with bottom blow down, it is important that operators monitor cycles closely and adjust frequency and length of time of blow down accordingly. This manual action is hard one to control cycles of concentration. surface blow down is used to control the cycle of centration of salts in water through blow down.

If the chloride level is higher than the recommended one, more blow down is needed. If it is low, excess blow down will result in wasted chemicals in water. In some cases, the chloride level never approaches the recommended maximum, even if little or no blowdown is being done.

With the blow down rate established, chemical feed can be done by dosing pump setting changes to bring residual chemical concentrations to the required level. Standard boiler chemical programs include

- Sodium hydroxide (caustic soda) for alkalinity
- Sodium sulfite for oxygen scavenging
- Phosphate for scale prevention
- Amines for return condensate treatment, which prevent condensate line corrosion and sludge deposition in the boiler.

The one of the parameters should be tested to maintain good boiler chemistry control is conductivity. The more materials are dissolved in the water, the higher its conductivity. As a boiler approaches its maximum allowable cycles, it will also approach its maximum allowable conductivity, Carryover resulting in excess fuel consumption and reduced efficiency. Measuring condensate and boiler water conductivities are important for ensuring good steam quality and can expose mechanical problems with boiler operation.

### III. CHEMICAL DOSING

#### SODIUM HYDROXIDE DOSING:

The sodium Hydroxide dosing is done in the boiler in order to provide high alkaline environment in the Boiler. This is added to Boiler feed water to prevent the acidic corrosion. Normally high temperature magnifies the corrosion in the boiler system since it speed up the chemical reaction. This dosing is used to increase the pH of the water.

#### SODIUM SULPHITE OR HYDRAZINE DOSING:

The boiler tubes gets damaged due to the concentration of oxygen in the water by tube pitting. Cold water holds more air. A deaerator can be used to heat the water with steam to remove oxygen, Normally Sodium Sulphite is used as a dosing chemical to remove the Oxygen


This chemical dosing is otherwise called as LP Dosing (Low Pressure Dosing). This dosing is used to remove the dissolved oxygen from the water. This chemical is added to the Low pressure side of the Boiler water system.

LP dosing is normally dosed in Deaerator or in the Boiler Feedwater pump suction line. Oxygen present in boiler feed water will erode tubes of a boiler. Water contains many elements that can either accumulate or erode the metal surfaces inside the boiler.


When water contains the dissolved Oxygen heated, the corrosive nature of these dissolved gases increases. As the temperature (and operating pressure) of a boiler increases, the destructive ability of O<sub>2</sub> increases.

Corrosion due to Oxygen causes severe metallic breakdown. Dissolved oxygen present in water and steam results in pitting of boiler.

Usually there are two chemicals used in LP dosing. One is Sodium Sulphite (Na<sub>2</sub>SO<sub>3</sub>) and another one is Hydrazine(N<sub>2</sub>H<sub>4</sub>).




Sodium Sulphite dosing is used for the low pressure Boilers as it increases the TDS of the water whereas Hydrazine is used in low pressure dosing for High pressure Boilers.



#### PHOSPHATE DOSING:

In order to remove the residual hardness and prevent scale formation due to accumulation of salts in the form of Calcium Chloride and Magnesium sulphate in the Boiler drum Phosphate Solution dosing is preferred.

Normally Tri sodium phosphate is dosed in the high pressure side of the Boiler. If the pH of water is less than 9.0 the calcium salts will not precipitate in the water. In order maintain the pH more than 9 and to make the calcium and magnesium salts to precipitate the Trisodium phosphate is dosed which are more Alkaline in nature. Tri sodium phosphate solution is prepared in the separate tank by mixing the Trisodium phosphate with the water and agitated with the Agitator for thorough mixing. After mixing with the water the Phosphate solution is dosed into the Steam drum by using the high pressure dosing pump. This Phosphate dosing is also called as high pressure dosing (HP dosing) as this dosing is done at the Boiler Drum which is at high pressure.




#### Phosphate hide out:

if the temperature of the boiler water increases beyond the limit the Solubility of Phosphate in the water decreases and deposited in the water tubes and performance of the boiler is less. If the temperature of the boiler water is in the allowable

range(200-350°C) and Phosphate will again reappear & Solubility of the Phosphate in water is optimum. This disappearing and appearing of Phosphate is termed as Phosphate hide out.

There is a relation between the Boiler load, pH and Phosphate. If the Boiler load increases the pH will increase and Residual Phosphate presence in water will be reduced. If the Boiler load decreases the pH will reduce and the Phosphate presence in water will increase and come to normal.



#### **AMINE DOSING:**

Most of the combined carbon dioxide is released with steam in the boiler and subsequently dissolves in the condensate, frequently causing corrosion problems.

Boiler corrosion occurs due to the presence and reaction of oxygen and carbon dioxide with iron in the boiler water system. This carbonic acid corrosion shall be rectified by Amine dosing.

CO<sub>2</sub> is dissolved in water in condensate to form carbonic acid (H<sub>2</sub>CO<sub>3</sub>). This carbonic acid reacts with steels and low alloys steels to form an iron carbonate scale. CO<sub>2</sub> corrosion is most typically found in condensate return systems.

The rate of corrosion in materials affected by CO<sub>2</sub> corrosion is dependent on several factors such as the concentration of CO<sub>2</sub> in the environment, the operating pressure and temperature, and the material composition.

Amine is dosed in the Condensate return line to increase the pH of the water. These condensate lines are of acidic in nature and cause Carbonic acid corrosion. In order to remove the carbonic acid Corrosion these amines are added to make water neutral or slightly alkaline.

#### **IV.CONCLUSION**

The boiler Chemical dosing system is a must require in overcoming the Boiler material failure from Scale, Sludge and Corrosion. From the above, it is clearly understood that the treatment of boiler feed water, Boiler water and Condensate water shall increase the life of the Boiler.

The addition of boiler chemical dosing and water treatment such as deaeration will ensure good operation and long life for boiler systems and its components. By maintaining optimal boiler water chemistry and preventing scale and corrosion, these chemicals contribute to improved efficiency and reduced maintenance costs.

#### **V. REFERENCE**

- [1] ASME/ABMA ( American Boiler Manufacturers Association)

#### **Disclaimer:**

The views and conclusions presented in this article are solely those of the author and cannot be ascribed to Fluor Corp. and/or any of its subsidiaries.

# IJEAST

INTERNATIONAL JOURNAL  
OF ENGINEERING APPLIED SCIENCE  
AND TECHNOLOGY

## ABOUT IJEAST

International Journal of Engineering Applied Science and Technology (IJEAST) is a peer-reviewed, open access journal that publishes high-quality research papers in the field of Engineering, Applied Science and Technology.

IJEAST aims to provide a platform for researchers, academicians, and professionals to share their innovative ideas, research findings, and practical experiences with the global scientific community.

## FOCUS AREAS

- Engineering
- Applied Science
- Technology
- Innovation & Development
- Interdisciplinary Studies



### PEER REVIEWED

All submissions are rigorously peer reviewed to ensure quality.



### OPEN ACCESS

Free and unrestricted access to research for all.



### GLOBAL REACH

Connecting researchers and professionals worldwide.



### TIMELY PUBLICATION

We ensure a swift and efficient publication process.



For more information, visit our website

**[www.ijeast.com](http://www.ijeast.com)**



**INTERNATIONAL JOURNAL**  
OF ENGINEERING APPLIED SCIENCE  
AND TECHNOLOGY

✉ [editor@ijeast.com](mailto:editor@ijeast.com)

🌐 [www.ijeast.com](http://www.ijeast.com)

📍 India



2455-2143